

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245749
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Monday, March 31, 2025

Corrective Action Required:

1	Misc	**SHALL INSTALL EROSION CONTROL AROUND THE STORM INLET AT REAR CORNER OF LOT **SUBMIT THE FOOTING INSPECTION FROM ENGINEER -Nail the sheathing to the LVL at west end -Shall submit footing inspection report before scheduling an inspection
---	------	--

Comments: