

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243956
Address: 3221 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Monday, March 31, 2025

Corrective Action Required:

1	Misc	-uncover covered garage portal frame nailing -fireblock furr out walls to ceiling space in garage (must be unfaced when using insulation) -seal top of furr out wall in great room left of fire place and front near dining room -columns in basement to be sized per plan
---	------	---

Comments: