



March 27, 2025

KC Concrete

Re: 1406/08 SW Winthrop Terrace
Lot 47 Woodland Glen
Lee's Summit Permit #: PRRES20245916

Apex Engineers, Inc. observed the preparation for the garage slabs at the above-referenced addresses.

The garage slabs will be suspended. The forms and reinforcing steel were found to be clean, well aligned, properly supported, and in general compliance with the approved prints.

Note:

- The inspection was performed at 1:40 pm
- Erosion control was in place at the time of the inspection.

Our firm recommends approval of the suspended garage slabs for the placement of concrete. This report does not constitute approval by the enforcing jurisdiction

LIMITATIONS

The recommendations and conclusions given in this report are based on the observed conditions at the time of this site visit. The scope of our services was only to observe the installation of the slab formwork and reinforcing steel.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,
Apex Engineers, Inc.

Clayton J. Hess, P.E.
Principal

