

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245022  
Address: 1613 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Mitchell Schwarz	Ready for Temp CO	Monday, March 31, 2025

Corrective Action Required:

1	Misc	Home locked no entry. 03/28/25
		-sod -provide as graded plot plan prior to sod -splash blocks and sump pump discharge to extend 36" from foundation -meter pit missing gravel -provide as graded plot plan -seal top of A/c disconnect

**Comments:**