

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245112
Address: 3215 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Monday, March 31, 2025

Corrective Action Required:

1 Misc

Pay all fees
-final grade and sod
-splash blocks and sump pump discharge to extend 36" from foundation
-bring meter ensure water meter is 14"-18" from top of meter to well ring lid
-provide as graded plot plan
-seal all exterior penetrations

Comments: