

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20246139  
Address: 2117 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Robb Popp	Not Ready	Monday, March 31, 2025

Informational:

1	Miscellaneous Correction	Partial inspection only: -PFH, front porch roof framing, covered deck framing and zip board approved to cover
---	--------------------------	--

Corrective Action Required:

2	Misc	-Provide truss plans, truss repair documentation and engineered floor joists for inspection. Full plan sets are required on site at time of inspections -Remove trash from site, maintain gravel filter and clean silt from streets
---	------	--

**Comments:**