

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246440
Address: 2769 SW 12TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Monday, March 31, 2025

Corrective Action Required:
2 Misc

- Fire block top of chase in pantry
- Fire block end of soffit in pantry
- Repair joist hanger great room at I- beam were bolt in the way
- Anchor bolts to be in middle of the plate in basement

Comments: