

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSITE20243891
Address: 3601 SW HOLLYWOOD DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection	Dustin Agcopra	Failed	Tuesday, April 01, 2025

Corrective Action Required:

1	Misc	9-25-24 Dustin A, Erosion control is in place. Sidewalk needs cleaned of debris from brush removal 10-11-24 Dustin A, ESC is established 10-15-24 Dustin A, ESC still up to standards 12-11-24 Dustin A, ESC is still established. No work being done 2-24-25 Dustin A, Erosion control is in place and maintained 4-1-25. Silt socks are full and holding trash and site is full of trash. Needs to be cleaned up.
---	------	--

Comments: