

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20245112
Address: 3215 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082
Inspected On: Tuesday, April 01, 2025
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Monday, March 31, 2025

Corrective Action Required:

1 Misc

Pay all fees
-final grade and sod
-splash blocks and sump pump discharge to extend 36" from foundation
-bring meter ensure water meter is 14"-18" from top of meter to well ring lid
-provide as graded plot plan
-seal all exterior penetrations

Comments: