



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20116035, Building Permit - Commercial
Address: 622 SW 3RD ST, Unit:G, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Failed	Wednesday, December 21, 2011

Corrective Action Required

1	MISC	NEC 380-10; 410-56(f) / IRC E3901.10; E3902.6 SECURING OF ELECTRICAL RECEPTACLES/SWITCHES: SOME NOT TIGHT TO BOX; CHECK ALL AND ENSURE NONE ARE "SOFT" OR LOOSE SIDE-TO-SIDE.
---	------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

Occupancy Inspection - Fire	Joe Dir	Passed	Wednesday, December 21, 2011
----------------------------------------	---------	--------	------------------------------

Comments: