

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235733
Address: 209 SE GREEN ST, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Underground Electrical Inspection - Commercial	Shawn Hoffman	Partial	Monday, March 10, 2025

Informational:

1 Misc

- Conduit from mech room 118 to west exterior
- Communication conduit from 118 to line 5 (108 mechanical)
- Conduit for (4) receptacles at SW corner of City Hall
- Conduit from SE sidewalk to NE corner and East to courtyard stairs and clocktower
- Christmas tree run at SE corner of city hall to quayside box roughly 15' from west side of building
- Ground ring with (3) ground rods at transformer location for service disconnect
- West side wicket inspection passed and is okay to cover
- East side wickets and ballard lighting
- East wicket, Ballard and holiday lighting
- Electrical street lighting conduit west side of Johnson street south of Cooper
- East side of Green street tree planters
- Corner of Green and 3rd conduit for (7) light poles and (5) tree receptacles
- South side of 3rd street (3) tree boxes and (3) light poles
- North side of 3rd street complete from Green to Johnson St
- South side of 3rd street complete from Green to Johnson St

- West side light poles and wickets conduit near city hall, boxes. Next to all 5

Informational:
2 Misc

wickets boxes not completed

- North East side lighting and wicket conduit in front of plaza area.

Comments: