CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244751
Address: 1025 SW ARMIE ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, April 01, 2025

Corrective Action Required:

4	Misc	- Seal floor penetration in master suite - Minimum of 3 studs required at exterior corners (return wall kitchen/ mud room and master/ laundry) - Fire block top of fireplace - Nail off East garage corner studs to code - Missing 1 joist of double joists in basement adjacent electrical panel

Comments: