

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242574  
Address: 366 NW PATCH CT, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Ready for Temp CO	Wednesday, April 02, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none"><li>- Provide gutters and downspouts</li><li>- Splash blocks</li><li>- Extend sump discharge to 36" away from foundation</li><li>- Final grading and sod</li></ul>
---	------	--

**Comments:**