

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244922
Address: 3205 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Wednesday, April 02, 2025

Corrective Action Required:

1 Misc

- CS-PF required at dining room. Missing. not framed to cspf specifications
- fire block master shower furr out wall to ceiling space(1/2" osb not approved fire blocking material)
- address holes drilled closer than 2" to each other above master bath (multiple spots)
- seal penetrations in RA joist space above laundry
- provide protection for dryer vent at top plate

Comments: