

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245749
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Wednesday, April 02, 2025

Corrective Action Required:

1	Misc	**4/2-Met Kyle on site
		**SHALL INSTALL EROSION CONTROL AROUND THE STORM INLET AT REAR CORNER OF LOT
		-Nail the sheathing to the LVL at west end

Comments: