

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20241108
Address: 2520 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Khanh Nguyen	Failed - Stop Work	Wednesday, April 02, 2025

Corrective Action Required

1	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED ALONG THE REAR OF LOT AND AT THE REAR LOT CORNER STORM INLET. FAILURE TO CORRECT THE EROSION CONTROL DEFICIENCY. LAST SCHEDULED INSPECTION WAS DENIED, BUT EROSION CONTROL DEFICIENCY HAS NOT BEEN CORRECTED. A STOP-WORK ORDER IS ISSUED.
---	----------------------------	--

Comments: