

Temporary Certificate of Occupancy

Permit #: PRRES20242574
Address: 366 NW PATCH CT, LEES SUMMIT, MO 64081
Inspected On: Wednesday, April 02, 2025
Inspected By: Development Center
Expiration Date: 4/9/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Ready for Temp CO	Wednesday, April 02, 2025

Corrective Action Required:

1	Misc	- Provide gutters and downspouts - Splash blocks - Extend sump discharge to 36" away from foundation - Final grading and sod
---	------	---

Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Monday, March 10, 2025
---	---------------	-------------------	------------------------

Corrective Action Required:

2	Misc	- Provide gutters and downspouts - Splash blocks - Extend sump discharge to 36" away from foundation - Final grading and sod
---	------	---

Comments: