

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243908
Address: 3449 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Wednesday, April 02, 2025

Corrective Action Required:

1	Misc	- Sump discharge is to be 36" away from foundation - Final grading - Final grading and sod - Provide gutters and downspouts with splash pads - Uncover water meter for inspection
---	------	--

Corrective Action Required:

2	Misc	EXTENTION REQUEST APPROVED
---	------	----------------------------

Comments: