

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246139
Address: 2117 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Wednesday, April 02, 2025

Corrective Action Required:

1	DCM1 ESC REQUIRED NO FURTHER INSP	3/31/25 EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -Remove trash, maintain gravel filter and clean silt from streets
---	---	---

Corrective Action Required:

2	DCM6 ESC INSP DENIED STREET CLEAN UP	**4/2/25 REQUESTED INSPECTION(S) DENIED. STREET CLEAN UP REQUIRED IMMEDIATELY, AND SHALL BE COMPLETED PRIOR TO REQUESTED INSPECTION(S) BEING PERFORMED. -INSTALL GRAVEL FILTER AS NOTED ON LAST INSPECTION REPORT. GRAVEL FILTER TO BE MIN 6" OF MIN 3/4" GRAVEL -CLEAN TIRE TRACKS THAT LEAD FROM SITE DOWN THE STREET. (THIS IS WHAT THE GRAVEL FILTER IS FOR) SEE PHOTOS UPLOADED ON PORTAL
---	--	---

Comments: