

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20246426  
Address: 1460 SE BROADWAY DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Bobby Richest	Partial	Thursday, April 03, 2025

Informational:

1	Misc	3-11-25 BR Silt fence is up but needs to add gutter buddies to storm boxes.
		3-20-25 BR Silt fence is up but needs to add gutter buddies to storm boxes.
		4-3-25 BR Silt fence is up and working but needs to add gutter buddies to storm boxes.

**Comments:**