


**RELEASED FOR
CONSTRUCTION**
As Noted on Plans Review
Development Services Department
Lee's Summit, Missouri
04/03/2025

CLARKSON BATCH PLANT
2250 NW QUARRY RD
LEES SUMMIT, MO. 6408




NOTE:

ALL CONDUCTORS SHALL BE RATED TO MATCH TERMINAL RATINGS OF THE EQUIPMENT AND OVERCURRENT PROTECTION DEVICES WHICH THEY ARE CONNECTED. 90°C CONDUCTORS FOR CIRCUITS RATED 100 AMPERES OR MORE. 75°C/90°C INSULATION

AVAILABLE FAULT CURRENT = 55,110 AMPS (VERIFY)
ALL SERVICE ENTRANCE AND DISTRIBUTION EQUIPMENT SHALL BE RATED TO ACCOMMODATE AND SAFELY INTERRUPT AVAILABLE FAULT CURRENT.

600A-KRP-C FUSES AT MAIN DISCONNECT
AIC RATING = 300,000 AMPS
AVAILABLE FAULT CURRENT
FROM EVERY = 55,000 AMPS
LET-THRU=10,000 AMPS



4/2/2025