

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #: PRCOM20240118  
Address: 515 NW MOORE ST, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Rated Assembly Inspection</b>	Robb Popp	Partial	Thursday, April 03, 2025

Corrective Action Required:  
1        Misc        -Complete fur downs around plumbing etc, seal penetrations at corridors  
  
                              -117 UP TO 417 SCREW PATTERN FOR HVAC CHASE UL301 2ND LAYER  
                              -118 UP TO 418 SCREW PATTERN FOR HAVC CHASE  
                              UL301 2ND LAYER  
                              -218 to 418 HVAC chase-north wall 1st layer

Corrective Action Required:  
2        ELEVATOR 1        -Shaft layer approved  
                              -1st and 2nd layer approved

Corrective Action Required:  
3        ELEVATOR 2        -Ceiling assembly complete

Corrective Action Required:  
4        STAIR TOWER 1

Corrective Action Required:  
5        STAIR TOWER 2        RC at ceilings ok

DRYWALL 1ST FLOOR SCREW PATTERN

Corrective Action Required:  
6        STAIR TOWER 3

Corrective Action Required:  
7        FIRST FLOOR        -RC at ceiling joists and 16" below ceiling at corridor walls from 135-108

- Screw pattern at corridor ceiling ok
- RC at units and corridor approved except as noted:

115-119 NOT READY  
136-NOT READY

Informational:

8 SECOND FLOOR

- RC at ceiling joists and 16" below ceiling at corridor walls from 235-208
- Screw pattern at corridor ceiling ok
- Screw pattern at corridor ceiling ok
- 217- 1st and 2nd layer at non shaft assembly walls both sides, both shafts
- 217- RC approved
- RC approved
- Screw pattern at units and corridor to firewall except as noted:

Informational:

9 THIRD FLOOR

- Screw pattern at corridor ceiling ok
- Pre rock behind showers at 335-332
- RC complete
- \*\*Screw pattern at units and corridor to firewall

Informational:

10 FOURTH FLOOR

- Screw pattern at corridor ceiling ok
- North mechanical shaft complete
- South mechanical shaft complete

- \*\*RC complete
- \*\*Screw pattern at units and corridor to firewall

Screw pattern at atrium- Install all missing screws per UL design, correct all gaps over 1/4"

- \*\*Update plans for new UL assembly on corridor and dividing walls

**Comments:**