



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20116035, Building Permit - Commercial
Address: 622 SW 3RD ST, Unit:G, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Commercial	John Borns	Not Ready	Thursday, December 22, 2011

Corrective Action Required

1	MISC	NEC 380-10; 410-56(f) / IRC E3901.10; E3902.6 SECURING OF ELECTRICAL RECEPTACLES & SWITCHES: SOME NOT TIGHT TO BOX; CHECK ALL AND ENSURE NONE ARE "SOFT" OR LOOSE SIDE-TO-SIDE. CHECK RECEPT IN NORTH RESTROOM FOR GFCI PROTECTION.
---	------	---

Corrective Action Required

2	MISC	12/22/11 NO ONE ON SITE
---	------	-------------------------

Final Building Inspection - Commercial	John Borns	Passed	Thursday, December 22, 2011
---	------------	--------	-----------------------------

Comments: OK PER SCOPE OUTLINED BY TRACY DEISTER IN INITIAL WALK-THROUGH. TENANT TO REPAIR ELECTRICAL RECEPTACLE IN NORTH RESTROOM -- NOT GFCI PROTECTED. NOTED THAT EXISTING RESTROOMS ARE NOT ADA COMPLIANT.