

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242328
Address: 3505 SE CORBIN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Friday, April 04, 2025

Corrective Action Required:

1	Miscellaneous Correction	- Land sewer trace wire to grade - Sump discharge to be 36" away from foundation - Install splash pads - Final grading and sod
		- Lower water meter and pit to grade

Informational:

2	Misc	EXTENTION REQUEST APPROVED Shawn Hoffman 04/04/2025 9:04 AM
---	------	--

Comments: