

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243549
Address: 1237 NE GOSHEN DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Khanh Nguyen	Failed	Friday, April 04, 2025

Corrective Action Required:

1	Misc	-Provide landscaping as required per plot plan -Screw the exterior garage door embedded jamb brace into studs through the four pre-drilled holes with min 3" screws
---	------	--

**TCO was issued on Feb-6. TCO is currently expire and must be extended or will be NOV status. All due fees (2 TCO fees) must be paid

Comments: