

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20231105

Address: 800 NW WARD RD, Unit:IR, LEES SUMMIT, MO 64086800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Miscellaneous Inspection	Robb Popp	Partial	Friday, April 04, 2025

Corrective Action Required:

1	Misc	Pre final for segment E: 4th Floor- 1446-Adjust door to self close and latch Sprinkler room-Install signage in corridor Fix smoke seals at fire door to D 3rd Floor- 2nd floor 1st floor: Sprinkler heads at storage units painted Provide landings at all egress doors 1155-Receptacles not working at kitchen G39-Seal penetrations S37-Sprinkler headed painted G34-Painted head, garage door CO device not working 1149-Gfci right of sink not working, smoke detector too close to range, install hand shower, install grab bars, GFCI at exterior not working G29-Fireproof paint missing at base of column
---	------	---

Comments: