

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235780
Address: 800 NW WARD RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pool Steel/Bonding - Commercial	Robb Popp	Passed	Monday, April 07, 2025

Informational:	
1 Misc	Components bonded -Pool shell, (4) points to deck, Skimmer basket to deck, Handrail sleeves at bottom of pool to deck, sleeve for ADA, perimeter surface back to equipment room

Comments: