

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242723
Address: 1054 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Monday, April 07, 2025

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Be aware of 6" clearance of siding to grade at back of house
- Outside outlets to be weather resistant

- Provide splash pads
- Land sewer trace wire to grade |
|---|------|--|

Comments: