



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115575, Building Permit - Commercial
Address: 880 NW BLUE PKWY, Unit:E, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Gas Piping Inspection - Commercial	Mark Harding	Failed	Tuesday, December 27, 2011

Corrective Action Required
1 MISC

ROOFTOP PIPING FOR CLAMPS TO WOOD BLOCKS, PIPE
MUST BE PAINTED AT OR BEFORE FINAL INSPECTION.
USE CORRECT CLAMPS-PAINT PIPING
RECALL WHEN COMPLETE

Gas Service Inspection - Commercial	Mark Harding	Passed	Tuesday, December 27, 2011
--	--------------	--------	----------------------------

Corrective Action Required
1 MISC

PERMIT PRINTS NOT FOUND AT JOBSITE

Comments: