

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20243943  
Address: 720 NE LONE HILL DR, LEES SUMMIT, MO 64064722 NE LONE HILL DR, LEES SUMMIT, MO  
64064718 NE LONE HILL DR, LEES SUMMIT, MO 64064

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Underslab Plumbing Inspection</b> <b>- Residential</b>	Khanh Nguyen	Failed	Monday, April 07, 2025

Corrective Action Required:

1	Misc	Lav drain cannot be used to wet-vent both the water closet and shower trap. Each trap in a wet-vented configuration must individually connect to the horizontal drain
---	------	---

**Comments:**