

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245536
Address: 1102 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Shawn Hoffman	Ready for Temp CO	Monday, April 07, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">- pay all outstanding fees- Pending sidewalk inspection- Provide sod- Provide splash pads- Seal all exterior penetrations- Sump discharge to be 36" away from foundation
---	------	---

Comments: