



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20112915, Building Permit - Commercial
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
In-wall Inspection	John Borns	Partial	Wednesday, December 28, 2011

Partial Correction
1 MISC

OK TO COVER WHEN READY WALL FRAMING AND IN-WALL SYSTEMS AT SPACES: 71; 72; 74; 75; 76; 77; 78; 78B; 79; 79B; 80; 81; 82 S,E,W; 83; 84; 85; 91; 92; 93; 94; 95 N WALL FROM 73 TO WEST; 98 W WALL; 155 SW CORNER; 162 N; 86; 88; 95 S WALL W OF DOOR 90A; 98 E WALL @ 93; 97 N WALL W OF DOOR 90B; 67;

Comments: