

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20242617  
Address: 2743 SW HEARTLAND RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Drew Fischer	Ready for Temp CO	Tuesday, April 08, 2025

Corrective Action Required:

1	Misc	NO FURTHER INSPECTIONS UNTIL EROSION CONTROL IN COMPLIANCE -provide as graded plot plan -sod -splash blocks and sump pump discharge to extend 36" from foundation -will check water meter at time of sod ensure water meter well to grade And meter 14"-18" from top of meter to well lid ring. 2" of gravel at bottom of meter pit
---	------	--

**Comments:**