

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244922  
Address: 3205 SW SADDLEBRED TER, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Drew Fischer	Failed	Tuesday, April 08, 2025

Corrective Action Required:

1	Misc	-CS-PF required at dining room. Missing. not framed to cspf specifications (missing king studs, missing nailing etc.) completed per detail -provide protection for dryer vent at top plate
---	------	---

**Comments:**