

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244024
Address: 3203 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Dustin Agcopra	Failed	Tuesday, April 08, 2025

Corrective Action Required:

1	Misc	- Erosion control in place at time of inspection.
---	------	---

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	3-6-25 Dustin A no erosion control in place EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. 3-13-25 Dustin A, Waddles have been put up. Esc needs to maintained until vegetation is established
---	----------------------------	---

Corrective Action Required:

3	DCM3 ESC REQUIRED 2 DAY	4/8/2025 Dustin A, all silt needs to be cleared from public sidewalk as well as the adjacent lot due to silt run off.
---	----------------------------	--

EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE
WITHIN TWO BUSINESS DAYS.

Comments: