

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245749
Address: 2524 NE WOODLAND OAK CIR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Khanh Nguyen	Partial	Wednesday, April 09, 2025

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	Erosion control is in compliance
---	---------------------------------------	----------------------------------

Comments: