

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20250835  
Address: 4001 SW MONDAVI LN, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Footing Inspection - Residential</b>	Shawn Hoffman	Passed	Wednesday, April 09, 2025

Informational:  
1 - Engineer report required spread footing of 24" with (3) #4 bars, this is in place.

UFER 1' back on south wall from front

**Comments:**