

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20216450  
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:             | Inspector:    | Outcome: | Date:                    |
|-------------------------|---------------|----------|--------------------------|
| <b>Pavement-Surface</b> | Bobby Richest | Passed   | Thursday, April 10, 2025 |

Informational:

|   |      |  |
|---|------|--|
| 1 | Misc | 11-12-24 BR Contractor installed 5" of KCMMB A-3 asphalt base on SE Silo St., SE Windbreak Dr., SE Cronin St. with 3rd party inspector (Ideker Inc.) getting 94% - 96% compaction.                   |
|   |      | 4-9-25 BR Contractor installed 2" of KCMMB A-2 asphalt surface on SE Silo St., SE Windbreak Dr., SE Cronin St. with 3rd party inspector (kansas city testing & engineering.) getting 95% compaction. |

**Comments:**