

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRSUBD20216450
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Pavement-Surface	Bobby Richest	Partial	Tuesday, November 12, 2024

Informational:

1	Misc	11-12-24 BR Contractor installed 5" of KCMMB A-3 asphalt base on SE Silo St., SE Windbreak Dr., SE Cronin St. with 3rd party inspector (Ideker Inc.) getting 94% - 96% compaction.
		4-9-25 BR Contractor installed 2" of KCMMB A-2 asphalt surface on SE Silo St., SE Windbreak Dr., SE Cronin St. with 3rd party inspector (kansas city testing & engineering.) getting 95% compaction.

Comments: