

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20222088  
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Pavement-Surface</b>	Bobby Richest	Partial	Tuesday, November 12, 2024

Informational:

1	Misc	11-12-24 BR Contractor installed 5" of KCMMB A-3 asphalt base on Windbreak Dr. & SE Vantage Point Dr. with 3rd party inspector (Ideker Inc.) getting 94% - 96% compaction.
		4-9-25 BR Contractor installed 2" of KCMMB A-2 asphalt surface on Windbreak Dr. & SE Vantage Point Dr. with 3rd party inspector (kansas city testing & engineering.) getting 95% compaction.

**Comments:**