

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20222088  
Address: 1400 SE RANSON RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Line - Coliform Test 1</b>	Bobby Richest	Passed	Thursday, April 10, 2025

Informational:  
1 Misc 4-2-25 BR 1st coliform 4 spot samples was taken on water line 1 & line 2.  
4-3-25 BR 1st coliform test samples was pass.

**Comments:**