

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242122
Address: 369 NW PATCH CT, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Failed	Thursday, April 10, 2025

Corrective Action Required:

1	Miscellaneous Correction	-Sidewalk inspection pending -As graded plot plan required -Pendant light above tub not permitted in main bath -Receptacles at deck will not trip -Break off set screw at anti siphon device
---	--------------------------	--

Comments: