

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242275
Address: 630 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Ready for Temp CO	Thursday, April 10, 2025

Corrective Action Required:

1	Miscellaneous Correction	-Complete corrections for all other departments -Install guard rail at walking surface where greater than 30" above grade
---	--------------------------	--

Comments: