

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20245134
Address: 3680 NE AKIN DR, Unit:134, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Rough Plumbing Inspection - Commercial	Khanh Nguyen	Failed	Thursday, April 10, 2025

Corrective Action Required:

1	Misc	-Protect plumbing at bottom wall track with BOCA plate -Install plumbing for ADA drinking fountain -Support cooler condensate drain pipe every 4 ft -Provide access to rooftop unit
---	------	--

Comments: