## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

## **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #: PRRES20250248

Address: 2758 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date: All Rough Inspection -Shawn Hoffman Failed Thursday, April 10, Residential 2025 Corrective Action Required: Misc 1 - No minimum overlap on top plate at entry wall/ kitchen at chase - Address bearing of 2x6 exterior stud stair way at porch rim joists - Bottom of Studs cut short at lower stairs landing OK to insulate

**Comments:**