

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245176
Address: 3219 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Thursday, April 10, 2025

Corrective Action Required:

1	Misc	<ul style="list-style-type: none">-provide as graded plot plan-final grade and sod-gutters missing-splash blocks and sump pump discharge to extend 36" from foundation-will check water meter at final grade-missing attic access cover-missing water heater discharge relief valve pipe-address over notched post at post to beam connection on deck-seal top of ac disconnect
---	------	---

Comments: