

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20241766  
Address: 2066 NW OBRIEN RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Robb Popp	Failed	Friday, April 11, 2025

Corrective Action Required:

1	Misc	- land sewer trace wire - final grading and sod - Provide gutters - Provide down spouts and splash blocks - Address center deck post cut flush **4/11/25 Notice of violation sent. TCO expired
---	------	---

**Comments:**