

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242294
Address: 1609 SW ARBORWAY TER, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|--------------|----------|------------------------|
| Occupancy Inspection - Codes Residential | Drew Fischer | Failed | Friday, April 11, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | sump pump discharge to extend 36" from foundation |
|---|------|---|

Comments: