

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244024
Address: 3203 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Drew Fischer	Failed	Friday, April 11, 2025

Corrective Action Required:

1	Misc	3203 -provide as graded plot plan -address pending driveway inspection -final grade and sod -splash blocks and sump pump discharge to extend 36" from foundation -ensure water meter well to grade And meter 14"-18" from top of meter to well lid ring. 2" of gravel at bottom of meter pit while maintaining serviceability of meter and setter. (Will check after time of sod)
---	------	--

Comments: