



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20112915, Building Permit - Commercial
Address: 80 NE SAINT LUKES BLVD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Concrete Walls and Columns Inspection	John Borns	Partial	Thursday, December 29, 2011

Partial Correction		
1	MISC	OK TO POUR WHEN READY RETAINING WALL FOR SIDEWALK OUTSIDE NORTH EXTERIOR BUILDING WALL

Above Ceiling Inspection	John Borns	Partial	Thursday, December 29, 2011
---------------------------------	------------	---------	-----------------------------

Partial Correction		
1	MISC	OK TO COVER WHEN READY ABOVE-CEILING TIE-IN EXTENSIONS OF WATER, HEATING WATER, SPRINKLER F.P., MED GAS, AND ELECTRICAL SYSTEMS @ EXISTING EXAM ROOMS 4,5, & 6

Partial Correction		
2	MISC	OK TO COVER WHEN READY CEILING FRAMING AND ABOVE-CEILING SYSTEMS AT SPACES: 162;

Comments: